2 INTERIOR ELEVATION 3 INTERIOR ELEVATION

> BALCONY (A) (A) 14' - 11 1/2" **(1)** 100 F (O) (O) 8'-3 3/4"

Looney Ricks Kiss

Architecture Planning Interiors Research 175 Toyota Plaza, Suite 600 Memphis, Tennessee 38103 Telephone 901 521 1440 Fax 901 525 2760 E-mail info@lrk.com

LOADSTAR, Inc.

9830 Colonnade Boulevard, Suite 600

San Antonio, Texas 78230

Date Issues 12.16.11 50% Design Development Design Development 50% CD 06.08.12 07.11.12 PRICING SET

No. Date 07/11/12 Addendum One

PERMIT SET

©2012 LRK Inc.
Drawings, written moterial, and design concepts shall not be used or reproduced in whole or part in any form or format without prior written consent of LRK Inc. Do not scale drawings.
Use given dimensions only. If not shown, verify correct dimensions with the Architect. Contractor shall check and verify all dimensions and conditions at job site.



Project Number: 01.11073.00

Project Name:

La Cantera Mixed Use

6215 Via La Cantera San Antonio, Texas 78256

837 NRSF

882 GRSF

Drawn By: BD, MF, DS Checked By: BD, BE

UNIT NOTES

ALL DIMENSIONS ON UNT PLANS ARE TO OUTSIDE FACE OF STUD OR CMU UNLESS NOTED THERMISE. STUDS NOT DIMENSIONED ARE 3 1/2 "MOOD STUDS TYPICAL UNLESS NOTED THERMISE.

2. ALL DIMENSIONS ARE BASED ON $5/8^\circ$ GYPSUM BOARD AT ALL INTERIOR BEARING AND ION-BEARING PARTITIONS.

KITCHEN BASE CABINETS ARE 24" DEEP AND BATH BASE CABINETS ARE 21" DEEP, TYP. 4, CLOSET SHELVES ARE MDF SHELVES AV NTEGRAL ROD. 15 IS ONE SHELF MOUNTED AT 5°T DEEP, TYP.

4, CLOSET SHELVES ARE MDF SHELVES AT 42° AND 34° AFF, 35 IS FIVE SHELVES AT 24°, 40°, 56°, 12°, AND 86° AFF, SHELVES AT UTILITY CLOSETS ARE MDF SHELVES, 25°/16 IS TAO HELVES, AT 10°C, AND 34° AFF, SHOE IS A VERTICAL SHOE RACK ISNEATH A SHELF.

5, SHELVES AT PANTRY AND LINEN CLOSETS ARE MDF SHELVES. 55/16 IS FIVE SHELVES, 16"-MIDE, MOUNTED AT 24", 40", 56", 12", AND 88" AFF.

VER FY EXACT DIMENSIONS REQUIRED TO INSTALL HVAC AND MATER HEATING QUIPMENT WITH MANUFACTURER BEFORE BUILDING ENCLOSURE MALLS AND FURR DOWNS.

8, CEMENTITIOUS BACKER BOARD SHALL BE USED AT ALL TUB/SHONER AREAS, MOISTURE RESISTANT GYPSUM BOARD MILL NOT BE ACCEPTED AT THESE LOCATIONS. 9, ALL INTERIOR UNIT WALLS AND CEILINGS ARE PAINTED " GYP, BOARD UNLESS NOTED OTHERWISE.

10. ALL INTERIOR UNIT WALLS TO HAVE PAINTED WOOD BASE TRIM INCLUDING MECHANICA UTILITY & COAT CLOSETS, UNLESS NOTED OTHERWISE, ALL CEILING HEIGHTS APPROX, 9-0" UNLESS NOTED THERWISE.

12. UNLESS NOTED OTHERNISE. SHADED AREA [[]] INDICATES THE LOCATION OF FURR-DOINS AT T-8 "TYPICAL. 3. REFER TO PROJECT DATA SHEET FOR PROJECT SQUARE FOOTAGE INFO 4. FOR WALL TYPES REFER TO SHEETS 2008-2008.

ALL WORK AND CONSTRUCTION SHALL MEET OR EXCEED ALL APPLICABLE CODES. , MOUNTING HEIGHT FOR TONEL BAR INSIDE SHONER IS 5'-0" A.F.F.

7. MOUNTING HEIGHT FOR TOWEL BAR NOT INSIDE SHOWER AND NOT ABOVE TOILET, IS 4-0" A.F.F. MOUNTING HEIGHT FOR T.P.H. IS 18" A.F.F. 3. ALL INTERIOR ELEVATIONS ARE DRAWN ASSUMING FINISH FACE OF GYPSUM BOARD

, PROVIDE FINISH PANELS AT ALL. EXPOSED END CONDITIONS OF CABINETS AND WHERE SHWASHER DOES NOT HAVE AN ADJACENT CABINET

D. PROVIDE BLOCKING TO ACCOMMODATE 42" UPPER CABINETS AT KITCHEN. I INSULATE ALL PLUMBING RISERS IN WALL WITH BATT INSULATION. 22. FOR ACCESSIBILITY REQUIREMENTS REGARDING ACCESSIBLE ROUTES AND PROTRUDIN ELEMENTS, REFER TO A 120 AND ANSI 117.1 2009 FOR MORE INFORMATION.

15. FOR ACCESSIBILITY REQUIREMENTS REGARDING THE PRIMARY AND SECONDARY INTRANCE DOORS, REFER TO A120 AND ANSI 117.1 2009 FOR MORE INFORMATION.

RT. FOR ACCESSIBILITY REQUIREMENTS REGARDING RENFORCING AROUND TOLLETS, TUBS IND SHOWERS, REFER TO A120 AND ANSI 117.1 2009 FOR MORE INFORMATION.

29. FOR ACCESSBILITY REQUIREMENTS REGARDING MANEUVERING AND CLEAR FLOOR SPACES, REFER TO A120 AND ANSI 117.1 2009 FOR MORE INFORMATION. 81, FOR ACCESSBILITY REQUIREMENTS REGARDING CLEARANCE AT KITCHEN AREAS, REFER TO A120AND ANSI 117,1 2009 FOR MORE INFORMATION.

32. MOUNTING ELEVATION FOR IPOD DOCING STATION IS 3'-6" AFF.

4 Unit A4