

LRK
Looney Ricks Kiss

Architecture Planning Interiors Research
175 Toyota Plaza, Suite 600
Memphis, Tennessee 38103
Telephone 901 521 1440
Fax 901 525 2760
E-mail info@lrk.com

Client:

LOADSTAR, Inc.

9830 Colonnade Boulevard, Suite
600
San Antonio, Texas
78230

Issues and Revisions

No.	Date	Issues
0	1/19/2012	GARAGE PERMIT
1	3/5/2012	PERMIT COMMENTS
2	3/21/2012	PERMIT COMMENTS
3	06/08/2012	PRICING SET
4	07/11/2012	BLDG PERMIT ISSUE
6	10/15/2012	FOR CONSTRUCTION SET

No.	Date	Revisions
-----	------	-----------

LEGEND

PROPERTY LINE

BUILDING STANDPIPE

HOSE LAY BY HAND 200 L.F. MAX

HOSE LAY BY TRUCK 750 L.F. MAX

PROPOSED FIRE TRUCK LANE

EXISTING FIRE/WATER SERVICE

PROPOSED FIRE/WATER SERVICE

EXISTING FIRE TRUCK LANE

PROPOSED SITE HARDSCAPE (REF.3/C420)

PROPOSED FIRE PROTECTION NOTES

BUILDING SIZE = REF. SHEETS A003 AND G002
OCCUPANCY TYPE = REF. SHEETS A003 AND G002
REQUIRED FIRE FLOW = 2,000 GALLONS/MINUTE
SPRINKLERED > 4 STORY
REQUIRED FIRE HYDRANTS = 2
AVAILABLE HYDRANTS = 4
ALLOWABLE TOTAL DISTANCE TO HYDRANT = 750'
ALLOWABLE HAND PULL = 200'


NOTE: REF. ARCHITECTURAL PLANS FOR STANDPIPE LOCATIONS AND BUILDING FIRE PROTECTION

AERIAL ACCESS REQUIREMENTS

- FULL NFPA 13 SYSTEM PROPOSED IN LIEU OF AERIAL ACCESS FOR BLDGS # A1,A2,B,C,F,G,H
- NFPA 13R SYSTEM PROPOSED FOR BLDGS D,E
- REF. ARCH SHEET A004a FOR DETAIL CALCS

©2010 LRK Inc.
Drawings, written material, and design concepts shall not be used or reproduced in whole or part in any form or format without prior written consent of LRK Inc. Do not scale drawings. Use given dimensions only. If not shown, verify correct dimensions with the Architect. Contractor shall check and verify all dimensions and conditions at job site.

Seal



PAPE-DAWSON
ENGINEERS
TExPE, FIRM REGISTRATION # 470

555 EAST RAMSEY | SAN ANTONIO, TEXAS 78216 | PHONE: 210.375.9001
FAX: 210.375.9011

Project Number: 7801-13

Project Number: 7801-13

Project Name: TOWN CENTER AT
LA CANTERA

La Cantera
Phase I
Market Street
San Antonio,
Texas

Drawing Name:

OVERALL SITE PLAN & FIRE PROTECTION PLAN

Drawn By: AA/CS/JG/DS

Checked By: WK/DLS

C100

